

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 16, 2008

POLYJOHN ENTERPRISES CORP RODNEY MULLETT 2500 GASPAR AVE WHITING IN 46394-2175

Re: Description: SEWAGE TANKS, POLYETHYLENE Manufacturer: POLYJOHN ENTERPRISES CORP

Product Name: HOLDING TANK

Model Number(s): Part Number - HT01-0300 (300 gallon capacity, White translucent in color)

Product File No: 20080583

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a
 licensed plumber or a holder of a servicing license issued pursuant to s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin.
 Code. All servicing and disposal of the contents from these tanks must be in accord with s. 146.20, Wis. Stats., and ch. NR
 113, Wis. Admin. Code.
- This product must be labeled with the manufacturer name and part number in a visible location after installation.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health and Family Services under ch. HFS 178.

This approval supersedes the approval issued on December 15, 2005 under product file number 20040045.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040045.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08058302.DOC